Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BL706

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NORTHERN VIEW MINK RANCH | Phone #:

Mailing Address: N11486 CTY A

City: TOMAHAWK | State: WI | Zip Code:

County	Co. Permit #	Notification #	Completed
Lincoln			11-07-1987

Well Constructor (Business Name): TERRENCE BECKLEY - NOKOMIS WELL & PUMP | Lic. # | Facility ID # (Public Wells)

Address | Well Plan Approval # | Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 4.5

3. Well serves # of Other

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

1. Well Location | Fire # (if avail.)

Town of BRADLEY

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W | Method Code

NE SW or Govt Lot #	Section	Township	Range
	11	35 N	6 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	68

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	Sand	Surface	68

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	New Steel Pipe ASTM A120 Taiwan W. H. Yaishing Ent. 18.97 lbs. per foot	Surface	53
6	Nominal Stainless Steel Screen #10	53	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

36 ft. _____ ground surface

10. Pump Test

Pumping level 47 ft. below surface

Pumping at 50 GP for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ?

Disinfected ?

Capped ?

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: