

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL707		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner NORTHERN VIEW MINK FARM Phone #						1. Well Location Fire # (if avail.)					
Mailing Address N11486 CTY A						Town of BRADLEY					
City TOMAHAWK State WI Zip Code						Street Address or Road Name and Number					
County Lincoln		Co. Permit #		Notification #		Completed 08-31-1987		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) TERRENCE BECKLEY - NOKOMIS WELL & PUMP				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code	
Address				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 11 35 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity		Construction Type					
3. Well serves # of Other Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? Hicap Property ? Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method						8. Geology					
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
6 Surface 62		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				S		Sand		Surface 62	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		34 ft. ____ ground surface				12 in. above grade	
6		New Steel Pipe ASTM A120 Taiwan 18.97 lbs per foot		Surface 51.5		10. Pump Test				Developed ?	
6		Nominal Stainless Steel Screen # 7		51.5 62		Pumping level 46 ft. below surface Pumping at 24 GP for 1 Hrs.				Disinfected ?	
Dia. (in.)		Screen type, material & slot size		From (ft.) To (ft.)		Pumping Method ?				Capped ?	
7. Grout or Other Sealing Material Method						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
						13. Constructor / Supervisory Driller		Lic #		Date Signed	
						Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: