

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL766		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BERNIE SCHOLZ					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address N8169 HWY E					Town of KING		Street Address or Road Name and Number						
City TOMAHAWK					State WI		Zip Code						
County Lincoln		Co. Permit #		Notification #		Completed 12-01-1987		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) RON KOMAREK - KOMAREK WELL				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code		
Address				Well Plan Approval #		°N °W		NW Section Township Range or Govt Lot # 29 35 N 7 E		2. Well Type New Well			
				Approval Date (mm-dd-yyyy)		of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?							
3. Well serves # of Home				Hicap Well ?		Construction Type							
Private, potable				Hicap Property ?									
Heat Exchange ____ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		206		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...			
								S		Sand Surface 140			
								C		Clay 140 205			
								G		Gravel 205 206			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		Steel ASTM A120 Taiwan YH .280 x 21' 18.97# Welded				Surface		206		55 ft. ____ ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test			
										Pumping level 80 ft. below surface Pumping at 30 GP for 48 Hrs. Pumping Method ?			
7. Grout or Other Sealing Material													
Method													
11. Well Is													
16 in. above grade Developed ? Disinfected ? Capped ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller										Lic #		Date Signed	
Drill Rig Operator										Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 08-18-2022

Review Status: