

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL777		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner CHARLES KAHN					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address N9923 SHOREWOOD RD.					Town of KING		Street Address or Road Name and Number						
City TOMAHAWK				State WI		Zip Code		Subdivision Name				Lot #	
County Lincoln		Co. Permit #		Notification #		Completed 10-20-1987		Block #					
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
TERRENCE BECKLEY - NOKOMIS WELL & PUMP				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 31 35 N 7 E		°N °W					
Address				Approval Date (mm-dd-yyyy)		2. Well Type New Well							
Hicap Permanent Well #				Common Well #		Specific Capacity		of previous unique well # constructed in					
3. Well serves # of Home				Hicap Well ?		Reason for replaced or reconstructed well ?							
Private, potable				Hicap Property ?		Construction Type							
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		64		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)			Yes				
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
S			Sand			Surface			30				
P C			Clay Hardpan			30			35				
S			Sand			35			64				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is	
6		New Steel Pipe ASTM A53B Plain End Venezuela 18.97 lbs. per foot				Surface		61.417		47 ft. _____ ground surface		10 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ?	
6		New Steel Pipe ASTM A53B Plain End Venezuela 18.97 lbs. per foot				Surface		61.417		Pumping level 56 ft. below surface		Disinfected ?	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP for 23 Hrs.		Capped ?	
6		New Steel Pipe ASTM A53B Plain End Venezuela 18.97 lbs. per foot				Surface		61.417		Pumping Method ?		Filled & Sealed Well(s) as needed?	
7. Grout or Other Sealing Material													
Method													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: