

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BL791		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner ARTHUR EVERSON					Phone #			1. Well Location				Fire # (if avail.)				
Mailing Address RFD 4								Town of HARRISON								
City RHINELANDER					State WI		Zip Code		Street Address or Road Name and Number							
County Lincoln		Co. Permit #		Notification #		Completed 06-04-1986		Subdivision Name				Lot #		Block #		
Well Constructor (Business Name) BRAD WEBSTER - RHINELANDER WELL DRILLING					Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address							Well Plan Approval #		SW SE		Section 2		Township 35 N		Range 8 E	
									Approval Date (mm-dd-yyyy)		2. Well Type New Well					
Hicap Permanent Well #					Common Well #		Specific Capacity				of previous unique well # constructed in					
3. Well serves # of Home					Hicap Well ?		Reason for replaced or reconstructed well ?									
Private, potable					Hicap Property ?		Construction Type									
Heat Exchange # of drillholes					Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)			From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6			Surface		32		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)									
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
Q		Y		Caving Sand & Gravel				Surface		20						
		C		Clay & Rock				20		27						
		G		Gravel				27		32						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		New Black Steel Plain End US Steel 19.97 lbs. Welded Open Bottom				Surface		32								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
7. Grout or Other Sealing Material																
Method																
9. Static Water Level																
13 ft. ____ ground surface																
10. Pump Test																
Pumping level 25 ft. below surface																
Pumping at 10 GP for 2 Hrs.																
Pumping Method ?																
11. Well Is																
14 in. above grade																
Developed ?																
Disinfected ?																
Capped ?																
12. Notified Owner of need to fill & seal ?																
Filled & Sealed Well(s) as needed?																
13. Constructor / Supervisory Driller																
				Lic #				Date Signed								
Drill Rig Operator				Lic or Reg #				Date Signed								

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: