

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BM363		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner GOLDBACH CORP.					Phone #			1. Well Location				Fire # (if avail.)							
Mailing Address							Town of PINE RIVER					Street Address or Road Name and Number							
City MARATHON				State WI		Zip Code			Subdivision Name					Lot #		Block #			
County Lincoln		Co. Permit #		Notification #			Completed 09-25-1979												
Well Constructor (Business Name) HUBERT J. LANG - LANG WELL DRILLING CO.					Lic. #		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address					Well Plan Approval #			°N		°W		NW Section Township Range or Govt Lot # 3 29 31 N 7 E							
								Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #			Common Well #			Specific Capacity			2. Well Type of previous unique well # constructed in Reason for replaced or reconstructed well ?										
3. Well serves # of Home Private, potable Heat Exchange ____ # of drillholes			Hicap Well ? Hicap Property ? Hicap Potable ?			Construction Type													
						4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method										8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		55		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)			S Sand Surface 4 A Y Coarse Sand & Coarse Gravel 4 55										
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		36 ft. ____ ground surface				12 in. above grade Developed ? Disinfected ? Capped ?					
6		19.45# ASTM A53 GR B USS Threaded & Coupled				Surface		53		10. Pump Test Pumping level 41 ft. below surface Pumping at 20 GP for 2 Hrs. Pumping Method ?									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
7. Grout or Other Sealing Material Method										13. Constructor / Supervisory Driller				Lic #		Date Signed			
Drill Rig Operator						Lic or Reg #		Date Signed											

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: