

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BM556		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																	
Property Owner STEVEN SEMLING					Phone #		1. Well Location				Fire # (if avail.)																
Mailing Address LAKE PESOBIC R 4					Town of MERRILL		Street Address or Road Name and Number																				
City MERRILL			State WI		Zip Code		Subdivision Name					Lot #		Block #													
County Lincoln		Co. Permit #		Notification #		Completed 10-09-1971		Latitude / Longitude in Decimal Degree (DD)					Method Code														
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)				°N		°W		NE SW Section Township Range													
JOE B. FISCHER				Well Plan Approval #		or Govt Lot #				36		32 N		6 E													
Address				Approval Date (mm-dd-yyyy)		2. Well Type																					
Hicap Permanent Well #				Common Well #		Specific Capacity				of previous unique well #				constructed in													
Heat Exchange ___ # of drillholes				Hicap Well ?		Hicap Property ?				Reason for replaced or reconstructed well ?				Construction Type													
3. Well serves # of Home														Hicap Potable ?													
Private, potable														Hicap Well ?													
4. Potential Contamination Sources - ON REVERSE SIDE																											
5. Drillhole Dimensions and Construction Method														8. Geology													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
6		Surface		40		Rotary - Mud Circulation				Rotary - Air				P		Hardpan				Surface		6					
Rotary - Air & Foam						Drill-Through Casing Hammer				Reverse Rotary				S		Sand				6		36					
Cable-tool Bit ___ in. dia...						Dual Rotary				Temp. Outer Casing ___ in. dia				G		Gravel				36		40					
Removed? ___ depth ft. (If NO explain on back side)						9. Static Water Level														11. Well Is							
6. Casing, Liner, Screen						Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)		To (ft.)		27 ft. _____ ground surface						12 in. above grade					
6 Black Steel 19.45#						Surface						40		10. Pump Test						Developed ?							
Dia. (in.) Screen type, material & slot size						From (ft.)						To (ft.)		Pumping level 32 ft. below surface						Disinfected ?							
7. Grout or Other Sealing Material						Method						Pumping at 10 GP for 1 Hrs.						Capped ?									
Pumping Method ?						12. Notified Owner of need to fill & seal ?																					
Filled & Sealed Well(s) as needed?						13. Constructor / Supervisory Driller														Lic #		Date Signed					
Drill Rig Operator						Lic or Reg #						Date Signed															

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: