

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BM682		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DONALD KRUEGER						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address R #1						Town of SCHLEY													
City GLEASON						State WI		Zip Code											
County Lincoln		Co. Permit #		Notification #		Completed 12-30-1978		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) BEN TORK				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address				Well Plan Approval #		SW SW		Section 23		Township 32 N		Range 8 E							
						or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well											
								of previous unique well # constructed in											
3. Well serves # of Restaurant / Bar Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? Hicap Property ? Hicap Potable ?		Reason for replaced or reconstructed well ?													
						Construction Type													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock											
10		Surface		23		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)													
6		23		Surface 60															
				60 75															
				75 90															
				90 90.5															
								90.5 125											
8. Geology																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		New Black Steel 19.45lbs. per foot C.-T. casing				Surface		78		U X		Sand & Clay		Surface		60			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		U C K		Clay, Cracked Rock		60		75			
										U Q		Blue Granite		75		90			
												Cracked Rock		90		90.5			
										U Q		Blue Granite		90.5		125			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
40 ft. _____ ground surface						16 in. above grade													
10. Pump Test												Developed ?							
Pumping level 125 ft. below surface												Disinfected ?							
Pumping at 3.5 GP for 8 Hrs.												Capped ?							
Pumping Method ?																			
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
Drilling Mud and Cuttings		Surface		12															
Neat Cement		12		23															
13. Constructor / Supervisory Driller												Lic #		Date Signed					
Drill Rig Operator												Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: