

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BN093		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ART BUCKS					Phone #		1. Well Location				Fire # (if avail.)						
Mailing Address							Town of BRADLEY										
City TOMAHAWK							State WI		Zip Code								
County Lincoln		Co. Permit #		Notification #		Completed 08-15-1956		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) A. J. HETZEL					Lic. #		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)			Method Code				
Address					Well Plan Approval #			SW SW Section Township Range or Govt Lot # 7 34 N 6 E		°N °W							
Approval Date (mm-dd-yyyy)					2. Well Type New Well												
Hicap Permanent Well #					Common Well #		Specific Capacity			of previous unique well #			constructed in				
Heat Exchange ____ # of drillholes					Hicap Well ?			Hicap Property ?			Reason for replaced or reconstructed well ?						
Private, potable					Hicap Potable ?			Construction Type									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
10 Surface 10			Rotary - Mud Circulation														
5 10 24			Rotary - Air														
			Rotary - Air & Foam														
			Drill-Through Casing Hammer														
			Reverse Rotary														
			Cable-tool Bit ____ in. dia...														
			Dual Rotary														
			Temp. Outer Casing ____ in. dia														
			Removed? ____ depth ft. (If NO explain on back side)														
8. Geology																	
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)								
10 Surface 10			Y			Sand & Gravel			Surface 10								
5 10 24			P			Hardpan			10 18								
			G			Gravel			18 24								
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
5		Steel				Surface		24		9 ft. ____ ground surface				12 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ?			
										Pumping level 15 ft. below surface				Disinfected ?			
										Pumping at 20 GP for 4 Hrs.				Capped ?			
										Pumping Method ?							
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?			
Method														Filled & Sealed Well(s) as needed?			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed	
Drilling Mud and Cuttings				Surface		10											
										Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: