

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BN261		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner ROBERT GOLEMGESKE						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address S10 W26165 HWY 18						Town of HARRISON						Street Address or Road Name and Number		
City WAUKESHA				State WI		Zip Code								
County Lincoln		Co. Permit #		Notification #		Completed 04-23-1977		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) ROBERT WEBSTER				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code			
Address				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range		
								NW SE		Section 15				Township 34 N
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well								
3. Well serves # of Home						Hicap Well ?		of previous unique well # constructed in						
								Reason for replaced or reconstructed well ?						
Private, potable						Hicap Property ?		Construction Type						
Heat Exchange ___ # of drillholes														Hicap Potable ?
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		277		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
K				Z				Clay & Gravel		Surface		276		
K				Q				Black Granite		276		277		
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		New Black Steel A53 US Steel 19.45# Threaded & Coupled				Surface		276						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		New Black Steel A53 US Steel 19.45# Threaded & Coupled				Surface		276						
7. Grout or Other Sealing Material														
Method														
9. Static Water Level														
27 ft. _____ ground surface														
10. Pump Test														
Pumping level 190 ft. below surface														
Pumping at 2 GP for 4 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ?														
Disinfected ?														
Capped ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
Drill Rig Operator				Lic or Reg #				Date Signed						

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: