

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BN421		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner FRED CHRISTENSEN						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address						Town of BRADLEY						Street Address or Road Name and Number											
City HEAFFORD JUNCTION				State WI		Zip Code																	
County Lincoln		Co. Permit #		Notification #		Completed 08-26-1965		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) H. S. HETZEL				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code												
Address				Well Plan Approval #		or Govt Lot #		Section 2		Township 35 N		Range 6 E											
				Approval Date (mm-dd-yyyy)		2. Well Type of previous unique well # constructed in																	
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?																	
3. Well serves # of Home				Hicap Well ?		Construction Type																	
Private, potable				Hicap Property ?																			
Heat Exchange ____ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
10		Surface		25		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)		S		Sand		Surface		30									
6		25		73.5						C		Clay		30		60							
										P		Hardpan		60		70							
										Y		Sand & Gravel		70		73.5							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. ____ ground surface				14 in. above grade									
6		Steel				Surface		73.5		10. Pump Test Pumping level 25 ft. below surface Pumping at 15 GP for 4 Hrs. Pumping Method ?				Developed ? Disinfected ? Capped ?									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller											
Method																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
Drilling Mud and Cuttings				Surface		25				Lic #				Date Signed									
												Drill Rig Operator				Lic or Reg #				Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: