

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8BN430		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																															
Property Owner RAYMOND W. CYCHOSZ						Phone #		1. Well Location				Fire # (if avail.)																													
Mailing Address						Town of BRADLEY						Street Address or Road Name and Number																													
City HEAFFORD JUNCTION				State WI		Zip Code																																			
County Lincoln		Co. Permit #		Notification #		Completed 12-20-1966		Subdivision Name				Lot #		Block #																											
Well Constructor (Business Name) HOWARD HETZEL				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code																											
Address				Well Plan Approval #				°N		°W		SW NW Section Township Range or Govt Lot # 2 35 N 6 E																													
				Approval Date (mm-dd-yyyy)																																					
Hicap Permanent Well #		Common Well #		Specific Capacity				2. Well Type New Well																																	
3. Well serves # of Other Private, potable Heat Exchange ___ # of drillholes						Hicap Well ?		of previous unique well # constructed in																																	
						Hicap Property ?		Reason for replaced or reconstructed well ?																																	
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type																																	
						Hicap Potable ?		Construction Type																																	
4. Potential Contamination Sources - ON REVERSE SIDE																																									
5. Drillhole Dimensions and Construction Method														8. Geology																											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)																					
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:5%;"></td> <td style="width:5%;">S</td> <td style="width:5%;">Sand</td> <td style="width:5%;"></td> <td style="width:5%;">Surface</td> <td style="width:5%;">35</td> </tr> <tr> <td></td> <td>C</td> <td>Clay</td> <td></td> <td>35</td> <td>70</td> </tr> <tr> <td></td> <td>P Z</td> <td>Hardpan & Boulders</td> <td></td> <td>70</td> <td>75</td> </tr> <tr> <td></td> <td>Y</td> <td>Sand & Gravel</td> <td></td> <td>75</td> <td>80</td> </tr> </table>					S	Sand		Surface	35		C	Clay		35	70		P Z	Hardpan & Boulders		70	75		Y	Sand & Gravel		75	80	Surface		35	
	S	Sand		Surface	35																																				
	C	Clay		35	70																																				
	P Z	Hardpan & Boulders		70	75																																				
	Y	Sand & Gravel		75	80																																				
6		20		80		35		70																																	
6		Steel		Surface		80		70		75																															
6		Steel		Surface		80		75		80																															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is																							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		26 ft. _____ ground surface				15 in. above grade																											
6		Steel				Surface		80		10. Pump Test				Developed ?																											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface				Disinfected ?																											
6		Steel				Surface		80		Pumping at 6 GP for 4 Hrs.				Capped ?																											
6		Steel				Surface		80		Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?																											
7. Grout or Other Sealing Material																																									
Method														13. Constructor / Supervisory Driller				Lic #		Date Signed																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Drill Rig Operator		Lic or Reg #						Date Signed																							
Drilling Mud and Cuttings				Surface		20		20		20		20		20																											

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: