Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8BN788

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: L. GRUBBS | Phone #:

Mailing Address: 4212 WASHINGTON

City: DOWNERS GROVE | State: IL | Zip Code:

County	Co. Permit #	Notification #	Completed
Lincoln			07-28-1966

Well Constructor (Business Name): DANIEL BEHM | Lic. # | Facility ID # (Public Wells)

Address | Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 2.5

3. Well serves # of Home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

1. Well Location

Town of HARRISON

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD) °N °W | Method Code

or Govt Lot #	Section	Township	Range
	1	35 N	8 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	39.5

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	Z	Boulders, Sand & Gravel	Surface	21
		Y		Sand & Small Gravel	21	39.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	Black Steel	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

21 ft. _____ ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ?

Disinfected ?

Capped ?

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: