

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8DT687		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BURGENDORF GREENHOUSES						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address R#2						Town of NEW HOLSTEIN									
City KIEL						State WI		Zip Code							
County Calumet		Co. Permit #		Notification #		Completed 04-24-1976		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) NORMAN WEBER				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.92055 °N -88.04254 °W				Method Code PAR001	
Address				Well Plan Approval #		NE NE		Section 25		Township 17 N		Range 20 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well						of previous unique well #		constructed in	
3. Well serves # of Other Private, potable Heat Exchange ___ # of drillholes						Hicap Well ?		Reason for replaced or reconstructed well ?							
						Hicap Property ?									
						Hicap Potable ?									
						Construction Type									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		28		Rotary - Mud Circulation									
6		28		131		<u>Yes</u> Rotary - Air									
						Rotary - Air & Foam									
						Drill-Through Casing Hammer									
						Reverse Rotary									
						Cable-tool Bit ___ in. dia...									
						Dual Rotary									
						Temp. Outer Casing ___ in. dia									
						Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
K		I		Black Soil				Surface		2					
R		C		Red clay				2		45					
U		C		Blue Clay				45		75					
		G		Gravel				75		127					
		L		Limestone				127		131					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		Steel				Surface		127							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
				Surface		28									
9. Static Water Level															
60 ft. _____ ground surface															
10. Pump Test															
Pumping level 70 ft. below surface															
Pumping at 30 GP for 2 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ?															
Disinfected ?															
Capped ?															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
				Lic #				Date Signed							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 07-12-2021

Review Status: