Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8DT748

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DONALD KEMPA			Phone #
Mailing Address: 829 BUCHANON			
City: KIEL	State: WI	Zip Code	
County: Calumet	Co. Permit #	Notification #	Completed: 06-17-1974

Well Constructor (Business Name): NORMAN WEBER	Lic. #	Facility ID # (Public Wells)	
Address		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

3. Well serves # of Home
Private,potable
Heat Exchange____# of drillholes
Hicap Well ?
Hicap Property ?
Hicap Potable ?

1. Well Location
Town of NEW HOLSTEIN
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD): 43.90638 °N -88.06197 °W
Method Code: PAR001
NE NE or Govt Lot # | Section: 36 | Township: 17 N | Range: 20 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	28
6	28	122

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		Topsoil	Surface	2
R		C		Red Clay	2	43
				Blue	43	84
		X		Sandy Clay	84	97
		L		Limestone	97	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Steel	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface	28	

9. Static Water Level
12 ft. _____ ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 25 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ?
Disinfected ?
Capped ?

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 07-12-2021 Review Status: