

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8DZ195		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WEILAND CONSTRUCTION					Phone #		1. Well Location				Fire # (if avail.)						
Mailing Address 930 LA CROSSE ST.					Town of CAMPBELL					Street Address or Road Name and Number OLIVET ST.							
City ONALASKA			State WI		Zip Code												
County La Crosse		Co. Permit #		Notification #		Completed 08-12-1986		Subdivision Name			Lot # Block #						
Well Constructor (Business Name) DANIEL RAHN				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code						
Address				Well Plan Approval #		SW Section Township Range		18 16 N 7 W		2. Well Type of previous unique well # constructed in							
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #			Common Well #		Specific Capacity		Reason for replaced or reconstructed well ? 										
3. Well serves # of Home				Hicap Well ?													
Private, potable				Hicap Property ?													
Heat Exchange ____ # of drillholes				Hicap Potable ?		Construction Type											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		63		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)		Y		Sand & Gravel		Surface		68			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. ____ ground surface				10 in. above grade Developed ? Disinfected ? Capped ?			
4		Steel				Surface		63		Pumping level 34 ft. below surface							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP for 2 Hrs.				Pumping Method ?			
7. Grout or Other Sealing Material Method										12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
								13. Constructor / Supervisory Driller				Lic #		Date Signed			
								Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: