

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FM718		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner WALDEMAR W LANGE Phone #						1. Well Location				Fire # (if avail.)	
Mailing Address 3920 WEST DOUGLAS AVE						Town of MEQUON				12037	
City MILWAUKEE State WI Zip Code						Street Address or Road Name and Number WEST BONNIWELL ROAD					
County Ozaukee		Co. Permit #		Notification #		Completed 06-13-1979		Subdivision Name		Lot #	Block #
Well Constructor (Business Name) ROBERT DEMERATH				Lic. #	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code		
Address				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 7 9 N 21 E	2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type				
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity							
3. Well serves # of Home Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? Hicap Property ? Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
10	Surface	20	Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)								
6	20	195									
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
C		Clay				Surface		58			
P		Hardpan				58		69			
G		Gravel				69		76			
L		Limestone				76		195			
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)					
6	Steel				Surface	76					
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)					
7. Grout or Other Sealing Material											
Method											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
Drilling Mud and Cuttings		Surface	20								
9. Static Water Level											
38 ft. ____ ground surface											
10. Pump Test											
Pumping level 45 ft. below surface Pumping at 20 GP for 8 Hrs. Pumping Method ?											
11. Well Is											
10 in. above grade Developed ? Disinfected ? Capped ?											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed?											
13. Constructor / Supervisory Driller											
Lic # Date Signed											
Drill Rig Operator Lic or Reg # Date Signed											

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: