Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8FW083

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LARRY PEIL | Phone #:

Mailing Address: RT. 1

City: BRANTWOOD | State: WI | Zip Code:

County	Co. Permit #	Notification #	Completed
Price			02-28-1977

Well Constructor (Business Name): BRADLEY WEBSTER - RHINELANDER WELL DRILLING, INC. | Lic. # | Facility ID # (Public Wells)

Address | Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.2

3. Well serves # of Home

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

1. Well Location

Town of KNOX

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD) °N °W | Method Code

NE SW or Govt Lot #	Section	Township	Range
	1	35 N	3 E

2. Well Type

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	122

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Z		Caving Gravel & Clay	Surface	34
		P		Hardpan & Boulders	34	86
	S	C		Soft Clay	86	114
K	S	Q		Soft Black Granite	114	122

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	New Black Steel 19.45#/ft. A53 US Steel Threaded & Coupled	Surface	114
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

16 ft. _____ ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 5 GP for 12 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ?

Disinfected ?

Capped ?

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: