

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW083		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LARRY PEIL					Phone #		1. Well Location Fire # (if avail.) Town of KNOX Street Address or Road Name and Number						
Mailing Address RT. 1													
City BRANTWOOD			State WI		Zip Code		Subdivision Name Lot # Block #						
County		Co. Permit #		Notification #		Completed							
Price						02-28-1977							
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
BRADLEY WEBSTER - RHINELANDER WELL DRILLING, INC.								°N °W					
Address				Well Plan Approval #		NE SW		Section		Township		Range	
				Approval Date (mm-dd-yyyy)		or Govt Lot #		1		35 N		3 E	
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type							
3. Well serves # of Home Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? Hicap Property ? Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		122		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
Q Z			Caving Gravel & Clay			Surface			34				
P			Hardpan & Boulders			34			86				
S C			Soft Clay			86			114				
K	S	Q	Soft Black Granite			114			122				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)		To (ft.)		9. Static Water Level 16 ft. _____ ground surface 10. Pump Test Pumping level 40 ft. below surface Pumping at 5 GP for 12 Hrs. Pumping Method ?				
6		New Black Steel 19.45#/ft. A53 US Steel Threaded & Coupled			Surface		114						
Dia. (in.)		Screen type, material & slot size			From (ft.)		To (ft.)		11. Well Is 15 in. above grade Developed ? Disinfected ? Capped ?				
7. Grout or Other Sealing Material Method													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 08-13-2024

Review Status: