Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8FW149

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HAROLD MATTISON			Phone #
Mailing Address: UNKNOWN			
City: CATAWBA	State: WI	Zip Code: 54515	
County: Price	Co. Permit #	Notification #	Completed: 04-05-1964

Well Constructor (Business Name): WILLIAM L. FIGURA	Lic. #: 2400	Facility ID # (Public Wells)	
Address: UNKNOWN BRUCE WI 54819		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.5	

1. Well Location

Village of CATAWBA

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name: GRUBER PAGE ADDITION	Lot #:	Block #: B

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SW SW or Govt Lot #:	Section: 5	Township: 35 N	Range: 1 W

2. Well Type

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	23

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	TOPSOIL	Surface	2
	HARD CLAY & GRAVEL MIX	2	78
	BLUE CLAY	78	81
	GRAVEL	81	94

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	STANDARD BLACK STEEL	Surface	94
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	23	

9. Static Water Level

42 ft. _____ ground surface

10. Pump Test

Pumping level 58 ft. below surface

Pumping at 8 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

8 in. above grade

Developed ? No

Disinfected ? No

Capped ? No

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: