

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW149		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HAROLD MATTISON						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address UNKNOWN						Village of CATAWBA													
City CATAWBA						State WI		Zip Code 54515											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #							
Price						04-05-1964		GRUBER PAGE ADDITION				Block # B							
Well Constructor (Business Name) WILLIAM L. FIGURA				Lic. # 2400		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address UNKNOWN BRUCE WI 54819				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SW		Section		Township		Range					
								or Govt Lot #		5		35 N		1 W					
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in											
3. Well serves # of HOME Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ? Construction Type													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		23		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ____ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ____ in. dia <u>No</u> Removed? ____ depth ft. (If NO explain on back side)						TOPSOIL		Surface		2			
												HARD CLAY & GRAVEL MIX		2		78			
												BLUE CLAY		78		81			
												GRAVEL		81		94			
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 42 ft. _____ ground surface				11. Well Is 8 in. above grade					
5		STANDARD BLACK STEEL				Surface		94		10. Pump Test Pumping level 58 ft. below surface Pumping at 8 GP M for 3 Hrs. Pumping Method ?				Developed ? No Disinfected ? No Capped ? No					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				No			
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement CLAY SLURRY Surface 23												Filled & Sealed Well(s) as needed?				No			
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-01-1960

Updated On: 07-28-2026

Review Status: