

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW302		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ANDREW KATULICK						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address								Town of HARMONY									
City PHILLIPS						State WI		Zip Code									
County		Co. Permit #		Notification #		Completed 08-08-1964		Subdivision Name				Lot #					
Price												Block #					
Well Constructor (Business Name) WILLIAM L FIGURA				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address						Well Plan Approval #		SW NW Section Township Range or Govt Lot # 15 36 N 1 W		2. Well Type of previous unique well # constructed in Reason for replaced or reconstructed well ?							
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity													
3. Well serves # of Home				Hicap Well ?													
Private, potable				Hicap Property ?													
Heat Exchange ____ # of drillholes				Hicap Potable ?				Construction Type									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology							
10		Surface		18		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		18		35						I		Top Soil		Surface		2	
										C		Clay		2		18	
										S		Sand		18		34	
										G		Gravel		34		35	
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level							
5		Standard Black Steel				Surface		35		9 ft. ____ ground surface							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test							
										Pumping level 20 ft. below surface							
										Pumping at 8 GP for 3 Hrs.							
										Pumping Method ?							
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
Clay Slurry				Surface		18											
11. Well Is 8 in. above grade Developed ? Disinfected ? Capped ?																	
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller								Lic #		Date Signed							
Drill Rig Operator								Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 08-13-2024

Review Status: