Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8FW440

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVID AMES	Phone #
Mailing Address: N1901 SCHALK RD. RR 1	
City: OGEMA	State: WI / Zip Code
County: Price	Co. Permit # / Notification # / Completed: 11-22-1987
Well Constructor (Business Name): RONALD KOMAREK	Lic. # / Facility ID # (Public Wells)
Address	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well # / Common Well #	Specific Capacity: 0.2
3. Well serves # of Farm: Private,potable	Hicap Well ? / Hicap Property ? / Hicap Potable ?
Heat Exchange____# of drillholes	

1. Well Location

Town of OGEMA	Fire # (if avail.): N1901
Street Address or Road Name and Number: SCHALK RD.	
Subdivision Name / Lot # / Block #	
Latitude / Longitude in Decimal Degree (DD): 45.44397 °N -90.39476 °W	Method Code: GPS008
SE NE or Govt Lot # / Section: 7 / Township: 34 N / Range: 1 E	

2. Well Type

of previous unique well # / constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	46

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	Hardpan	Surface	45
Y	Sand - Gravel	45	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	VSP .280 Wall 19.45#/ft. 1200# psi Threaded & Coupled	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

6 ft. _____ ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 6 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ?

Disinfected ?

Capped ?

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drilling Mud and Cuttings	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: