

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW440		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DAVID AMES						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address N1901 SCHALK RD. RR 1								Town of OGEMA				N1901	
City OGEMA						State WI		Zip Code					
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #	
Price						11-22-1987						Block #	
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
RONALD KOMAREK								45.44397 °N -90.39476 °W				GPS008	
Address				Well Plan Approval #		SE NE		Section		Township		Range	
				Approval Date (mm-dd-yyyy)		or Govt Lot #		7		34 N		1 E	
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type					
								of previous unique well # constructed in					
								Reason for replaced or reconstructed well ?					
3. Well serves # of Farm				Hicap Well ?				Construction Type					
Private, potable				Hicap Property ?									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 20													
6 20 46			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
P			Hardpan						Surface 45				
Y			Sand - Gravel						45 46				
6. Casing, Liner, Screen													
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)						
6			VSP .280 Wall 19.45#/ft. 1200# psi Threaded & Coupled				Surface		46				
Dia. (in.)			Screen type, material & slot size				From (ft.) To (ft.)						
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement								
Drilling Mud and Cuttings			Surface		20								
9. Static Water Level													
6 ft. _____ ground surface													
10. Pump Test													
Pumping level 40 ft. below surface													
Pumping at 6 GP for 1 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ?													
Disinfected ?													
Capped ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #			Date Signed										
Drill Rig Operator			Lic or Reg #						Date Signed				

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 07-28-2026

Review Status: