

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW461		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RUSSELL G. NASLUND						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address RR 2						Town of HILL						W4776	
City OGEMA						State WI		Zip Code				Street Address or Road Name and Number	
HARRISON RD.						Subdivision Name				Lot #		Block #	
County		Co. Permit #		Notification #		Completed		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Price						11-24-1986		°N		°W			
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		NE		SW		Section	
RONALD KOMAREK								Township		Range			
Address				Well Plan Approval #		or Govt Lot #		7		34 N		2 E	
Approval Date (mm-dd-yyyy)								2. Well Type					
Hicap Permanent Well #				Common Well #		Specific Capacity		of previous unique well #					
								constructed in					
								Reason for replaced or reconstructed well ?					
								Construction Type					
3. Well serves				# of Home		Hicap Well ?							
Private, potable						Hicap Property ?							
Heat Exchange				# of drillholes		Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
10		Surface		20									
6		20		141									
						Rotary - Mud Circulation							
						Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ____ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ____ in. dia							
						Removed? ____ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
P G		Hardpan - Gravel		Surface		25							
Y		Sand - Gravel		25		141							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		VSP 19.45#/ft. ASTM A120 1200#psi Threaded & Coupled				Surface		141					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
Drilling Mud and Cuttings		Surface		20									
9. Static Water Level													
10 ft. ____ ground surface													
10. Pump Test													
Pumping level 18 ft. below surface													
Pumping at 10 GP for 15 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ?													
Disinfected ?													
Capped ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
Drill Rig Operator		Lic or Reg #		Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 07-28-2026

Review Status: