

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW511		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner LAWRENCE NELSON						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address RR 1						Town of OGEMA						N2559		
City OGEMA						State WI		Zip Code				Street Address or Road Name and Number		
County						Co. Permit #		Notification #				Completed		
Price						11-02-1987		Subdivision Name				Lot #		
Block #						Latitude / Longitude in Decimal Degree (DD)						Method Code		
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)				45.46804 °N -90.31142 °W		
RONALD KOMAREK - KOMAREK WELL						Well Plan Approval #		SE SE				Section Township Range		
Address						Approval Date (mm-dd-yyyy)		or Govt Lot # 35 35 N 1 E				2. Well Type		
Hicap Permanent Well #						Common Well #		Specific Capacity				of previous unique well # constructed in		
3. Well serves # of Home						Hicap Well ?		Reason for replaced or reconstructed well ?				Construction Type		
Private, potable						Hicap Property ?		Heat Exchange ___ # of drillholes				Hicap Potable ?		
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock		
10			Surface			20			Rotary - Mud Circulation			Rotary - Air		
6			20			105			Rotary - Air & Foam			Drill-Through Casing Hammer		
									Reverse Rotary					
									Cable-tool Bit ___ in. dia...					
									Dual Rotary					
									Temp. Outer Casing ___ in. dia					
									Removed? ___ depth ft. (If NO explain on back side)					
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
P			Hardpan			Surface			100					
Y			Sand - Gravel			100			105					
6. Casing, Liner, Screen														
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)			To (ft.)					
6			18.97#/ft. ASTM A120 .280 Wall Taiwan YH Welded Joints			Surface			105					
Dia. (in.)			Screen type, material & slot size			From (ft.)			To (ft.)					
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material			From (ft.)			To (ft.)			# Sacks Cement					
Drilling Mud and Cuttings			Surface			20								
9. Static Water Level														
32 ft. _____ ground surface														
10. Pump Test														
Pumping level 85 ft. below surface														
Pumping at 20 GP for 2 Hrs.														
Pumping Method ?														
11. Well Is														
18 in. above grade														
Developed ?														
Disinfected ?														
Capped ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #			Date Signed											
Drill Rig Operator			Lic or Reg #			Date Signed								

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-01-2023

Review Status: