

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW530		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner PAUL WOLLEMANN						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 7000 W. LIMA ST.						Town of KNOX						N3647					
City MILWAUKEE						State WI		Zip Code				Street Address or Road Name and Number					
County						Co. Permit #		Notification #				Completed					
Price						09-11-1987						CTH D					
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)					
RONALD KOMAREK - KOMAREK WELL												Method Code					
						Well Plan Approval #		45.50846 °N -90.10454 °W				GPS008					
Address						Approval Date (mm-dd-yyyy)		NE NE Section Township Range or Govt Lot # 21 35 N 3 E									
Hicap Permanent Well #						Common Well #		Specific Capacity				2. Well Type					
												of previous unique well # constructed in					
3. Well serves # of Home						Hicap Well ?		Reason for replaced or reconstructed well ?									
Private, potable						Hicap Property ?											
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock									Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
10 Surface 20			Rotary - Mud Circulation											Hardpan		Surface 70	
6 20 75			Rotary - Air														
			Rotary - Air & Foam											Gravel		70 75	
			<u>Yes</u> Drill-Through Casing Hammer														
			Reverse Rotary														
			Cable-tool Bit ___ in. dia...														
			Dual Rotary														
			Temp. Outer Casing ___ in. dia														
			Removed? ___ depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.) To (ft.)		35 ft. _____ ground surface		10 in. above grade				
6			Plain End Steel 18.97#/ft. ASTM A120 YH Taiwan						Surface		75		Developed ?				
Dia. (in.)			Screen type, material & slot size						From (ft.) To (ft.)		Pumping level 50 ft. below surface		Disinfected ?				
													Capped ?				
7. Grout or Other Sealing Material												Pumping at 6 GP for 20 Hrs.					
Method												Pumping Method ?					
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement							12. Notified Owner of need to fill & seal ?					
Clay Slurry			Surface 20									Filled & Sealed Well(s) as needed?					
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 07-28-2026

Review Status: