

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FW867		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOE KMET					Phone #			1. Well Location				Fire # (if avail.)							
Mailing Address								Town of ELK				W11779							
City					State WI		Zip Code		Street Address or Road Name and Number										
County					Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #		
Price							02-18-1965												
Well Constructor (Business Name)					Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code						
WILLIAM L FIGURA									45.71175 °N -90.66791 °W				GPS008						
Address							Well Plan Approval #		SW SE		Section		Township		Range				
							Approval Date (mm-dd-yyyy)		or Govt Lot #		6		37 N		2 W				
Hicap Permanent Well #					Common Well #		Specific Capacity		2. Well Type										
									of previous unique well #				constructed in						
									Reason for replaced or reconstructed well ?										
3. Well serves # of Restaurant / Bar					Hicap Well ?														
Private, potable					Hicap Property ?														
Heat Exchange ___ # of drillholes					Hicap Potable ?				Construction Type										
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method													8. Geology						
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		12		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Z		Gravel & Clay Mix		Surface		9	
5		12		49								G		Gravel		9		12	
												N S		Fine Sand		12		39	
												G		Gravel		39		49	
6. Casing, Liner, Screen													9. Static Water Level		11. Well Is				
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. _____ ground surface		10 in. above grade							
5		Standard Black Steel				Surface		49		10. Pump Test		Developed ?							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 35 ft. below surface		Disinfected ?							
										Pumping at 10 GP for 2 Hrs.		Capped ?							
										Pumping Method ?									
7. Grout or Other Sealing Material													12. Notified Owner of need to fill & seal ?						
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
Clay Slurry				Surface		12													
													13. Constructor / Supervisory Driller		Lic #		Date Signed		
Drill Rig Operator													Lic or Reg #		Date Signed				

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 08-13-2024

Review Status: