

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FX043		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MICHAEL WATRAL					Phone #		1. Well Location				Fire # (if avail.)						
Mailing Address LUGER RT					Town of FLAMBEAU					N9771							
City				State WI		Zip Code		Street Address or Road Name and Number STH 13									
County		Co. Permit #		Notification #		Completed 07-30-1959		Subdivision Name			Lot # 1		Block #				
Well Constructor (Business Name) WILLIAM HOLT				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.72539 °N -90.43038 °W			Method Code GPS008						
Address				Well Plan Approval #		SE SE		Section 36		Township 38 N		Range 1 W					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		36		38 N		1 W					
Hicap Permanent Well #			Common Well #			Specific Capacity			2. Well Type of previous unique well # constructed in								
Hicap Well ?			Hicap Property ?			Hicap Potable ?			Reason for replaced or reconstructed well ?								
Private, potable			Heat Exchange ___ # of drillholes			Construction Type											
3. Well serves # of Home																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
14		Surface		18		Rotary - Mud Circulation				Rotary - Air							
6		18		89		Rotary - Air & Foam				Drill-Through Casing Hammer							
Reverse Rotary						Cable-tool Bit ___ in. dia...											
Dual Rotary						Temp. Outer Casing ___ in. dia											
Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology							
6		Galvanized Steel				Surface		75		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		P		Hardpan		Surface		73	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Bedrock		73		89			
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		9. Static Water Level							
Puddled Clay				Surface		18		24 ft. _____ ground surface		11. Well Is							
10. Pump Test																	
Pumping level 45 ft. below surface																	
Pumping at 8 GP for 6 Hrs.																	
Pumping Method ?																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller																	
Lic #																	
Date Signed																	
Drill Rig Operator																	
Lic or Reg #																	
Date Signed																	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 08-13-2024

Review Status: