

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8FX102		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner JOSEPH M BIROSAK						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address								Town of FIFIELD				N14018		
City FIFIELD						State WI		Zip Code						
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		
Price						01-24-1964						Block #		
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code		
WILLIAM HOLT								45.88208 °N -90.39619 °W				GPS008		
Address				Well Plan Approval #		NE NE		Section		Township		Range		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		7		39 N		1 E		
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type						
								of previous unique well #						
								Reason for replaced or reconstructed well ?						
3. Well serves # of Farm				Hicap Well ?				Construction Type						
Private, potable				Hicap Property ?										
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock		
12			Surface			17								
5			17			76								
									Rotary - Mud Circulation					
									Rotary - Air					
									Rotary - Air & Foam					
									Drill-Through Casing Hammer					
									Reverse Rotary					
									Cable-tool Bit ___ in. dia...					
									Dual Rotary					
									Temp. Outer Casing ___ in. dia					
									Removed? ___ depth ft. (If NO explain on back side)					
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
P			Hardpan			Surface			71					
G			Gravel			71			76					
6. Casing, Liner, Screen														
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)			To (ft.)					
5			Steel			Surface			76					
Dia. (in.)			Screen type, material & slot size			From (ft.)			To (ft.)					
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material			From (ft.)			To (ft.)			# Sacks Cement					
Puddled Clay			Surface			76								
9. Static Water Level														
32 ft. _____ ground surface														
10. Pump Test														
Pumping level 39 ft. below surface														
Pumping at 10 GP for 7 Hrs.														
Pumping Method ?														
11. Well Is														
10 in. above grade														
Developed ?														
Disinfected ?														
Capped ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #			Date Signed											
Drill Rig Operator			Lic or Reg #			Date Signed								

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 07-08-2025

Review Status: