

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HF531		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RANDY PULVERMACHER					Phone #		1. Well Location				Fire # (if avail.)				
Mailing Address RR # 2					Town of SPRING GREEN										
City SPRING GREEN					State WI		Zip Code								
County Sauk		Co. Permit #		Notification #		Completed 12-09-1987		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) TONY PREM					Lic. #		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 43.21519 °N -90.13558 °W			Method Code GPS008		
Address					Well Plan Approval #			SE NE		Section 33		Township 9 N		Range 3 E	
Approval Date (mm-dd-yyyy)					2. Well Type of previous unique well # constructed in										
Hicap Permanent Well #			Common Well #		Specific Capacity			Reason for replaced or reconstructed well ?							
3. Well serves # of Home					Hicap Well ?			Construction Type							
Private, potable					Hicap Property ?										
Heat Exchange ___ # of drillholes					Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 78			Rotary - Mud Circulation												
6 78 116			Rotary - Air												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Yes Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ___ in. dia												
Removed? ___ depth ft. (If NO explain on back side)															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Y				Sand & Gravel				Surface		78					
S N				Soft Sandstone				78		105					
H N				Firm Sandstone				105		116					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 75 ft. _____ ground surface					
6 Steel		Surface				105									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material										10. Pump Test					
Method										Pumping level 77 ft. below surface					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Pumping at 14 GP for 5 Hrs.							
Drilling Mud and Cuttings		Surface		78				Pumping Method ?							
Filled & Sealed Well(s) as needed?										11. Well Is 14 in. above grade Developed ? Disinfected ? Capped ?					
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-01-2023

Review Status: