Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8HF565

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WYTTENBACH FARMS | Phone #:

Mailing Address: RR # 1

City: PRAIRIE DU SAC | State: WI | Zip Code:

County	Co. Permit #	Notification #	Completed
Sauk			04-22-1982

Well Constructor (Business Name): MARVIN HOLZEN | Lic. #:

Address:

Facility ID # (Public Wells):

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #: | Common Well #: | Specific Capacity: 46.2

3. Well serves # of Irrigation

Private,potable

Heat Exchange____# of drillholes

Hicap Well ?

Hicap Property ?

Hicap Potable ?

1. Well Location

Town of PRAIRIE DU SAC

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 43.26565 °N -89.77185 °W

Method Code: GPS008

SE SW or Govt Lot # | Section: 10 | Township: 9 N | Range: 6 E

2. Well Type

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
17	Surface	109

Upper Enlarged Drillhole | Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	Sand	Surface	30
Y	Sand and gravel	30	109

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
14	Steel	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

18 ft. _____ ground surface

10. Pump Test

Pumping level 44 ft. below surface

Pumping at 1200 GP for 4 Hrs.

Pumping Method ?

11. Well Is

13 in. above grade

Developed ?

Disinfected ?

Capped ?

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drilling Mud and Cuttings	Surface	70	
	70	109	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: