Well Construction Report
WISCONSIN UNIQUE WELL NUMBER 8HF718

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHARLES DABROTY | Phone #:

Mailing Address:

City: MERRIMAC | State: WI | Zip Code:

County: Sauk | Co. Permit # | Notification # | Completed: 10-26-1981

Well Constructor (Business Name): LAVERNE WELSCH | Lic. # | Facility ID # (Public Wells)

Address | Well Plan Approval # | Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity

3. Well serves # of Other
Private,potable
Heat Exchange____# of drillholes
Hicap Well ?
Hicap Property ?
Hicap Potable ?

1. Well Location
Town of MERRIMAC
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD): 43.38946 °N -89.60528 °W | Method Code: GPS008
SE NE or Govt Lot # | Section: 36 | Township: 11 N | Range: 7 E

2. Well Type
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
6	15	330

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	Topsoil	Surface	4
S	Sand	4	125
Y	Sand & Gravel	125	255
N	Sandstone	255	330

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	Steel	Surface	307
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Drilling Mud and Cuttings	Surface	15	

9. Static Water Level
60 ft. _____ ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 25 GP for 15 Hrs.
Pumping Method ?

11. Well Is
_____ in. above grade
Developed ?
Disinfected ?
Capped ?

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 01-01-1960 Updated On: 06-30-2022 Review Status: