

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HF718		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner CHARLES DABROT Y						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address								Town of MERRIMAC					
City MERRIMAC						State WI		Zip Code					
County Sauk		Co. Permit #		Notification #		Completed 10-26-1981		Subdivision Name				Lot #	
												Block #	
Well Constructor (Business Name) LAVERNE WELSCH				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.38946 °N -89.60528 °W				Method Code GPS008	
Address				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NE		Section 36		Township 11 N	
								Range 7 E					
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in					
								Reason for replaced or reconstructed well ?					
								Construction Type					
3. Well serves # of Other												Hicap Well ?	
Private, potable								Hicap Property ?					
Heat Exchange ___ # of drillholes								Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 15													
6 15 330			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)		
			I Topsoil						Surface		4		
			S Sand						4		125		
			Y Sand & Gravel						125		255		
			N Sandstone						255		330		
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		Steel				Surface		307					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
Drilling Mud and Cuttings				Surface		15							
9. Static Water Level													
60 ft. _____ ground surface													
10. Pump Test													
Pumping level 60 ft. below surface													
Pumping at 25 GP for 15 Hrs.													
Pumping Method ?													
11. Well Is													
_____ in. above grade													
Developed ?													
Disinfected ?													
Capped ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: