

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HF726		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PAUL KRAMER						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address RT 1						Town of IRONTON						Street Address or Road Name and Number			
City LAVALLE				State WI		Zip Code									
County Sauk		Co. Permit #		Notification #		Completed 01-13-1987		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ALBIN HERBECK				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.51859 °N -90.15345 °W				Method Code GPS008	
Address				Well Plan Approval #		SW		Section 16		Township 12 N		Range 3 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #		16		12 N		3 E			
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in									
Hicap Well ?		Hicap Property ?		Hicap Potable ?		Reason for replaced or reconstructed well ?									
3. Well serves # of Home				Private, potable		Construction Type									
Heat Exchange ___ # of drillholes				Hicap Well ?		Hicap Property ?									
Hicap Potable ?				Hicap Potable ?		Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 42			Rotary - Mud Circulation												
6 42 180			Rotary - Air												
Yes			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ___ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ___ in. dia												
Removed? ___ depth ft. (If NO explain on back side)			Pumping level 153 ft. below surface												
			Pumping at 7 GP for 24 Hrs.												
Pumping Method ?			Pumping Method ?												
6. Casing, Liner, Screen															
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.) To (ft.)						
6 Steel			Surface						42						
Dia. (in.)			Screen type, material & slot size						From (ft.) To (ft.)						
Neat Cement			8 42						8 42						
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement										
Surface			8		8										
Neat Cement			8		42										
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)						
I			Topsoil						Surface 1						
C			Clay						1 8						
H			Shale						8 63						
N			Sandstone						63 180						
9. Static Water Level															
104 ft. _____ ground surface															
10. Pump Test															
Pumping level 153 ft. below surface															
Pumping at 7 GP for 24 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ?															
Disinfected ?															
Capped ?															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
Lic #			Date Signed												
Drill Rig Operator			Lic or Reg #												
Date Signed			Date Signed												

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: