

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HF753		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner WALTER KLITZKE					Phone #			1. Well Location				Fire # (if avail.)									
Mailing Address RR #1					Town of REEDSBURG			Street Address or Road Name and Number				Subdivision Name		Lot #		Block #					
City ROCK SPRINGS			State WI		Zip Code			Subdivision Name				Lot #		Block #							
County Sauk		Co. Permit #		Notification #			Completed 07-08-1986			Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name) WILLIAM H. SMITH					Lic. #		Facility ID # (Public Wells)			°N °W				NE SW Section Township Range or Govt Lot # 36 12 N 4 E							
Address					Well Plan Approval #			Approval Date (mm-dd-yyyy)				2. Well Type New Well									
Hicap Permanent Well #					Common Well #		Specific Capacity			Reason for replaced or reconstructed well ?				Construction Type							
3. Well serves # of Home					Hicap Well ?			Private, potable				Hicap Property ?									
Heat Exchange ___ # of drillholes					Hicap Potable ?			Reason for replaced or reconstructed well ?				Construction Type									
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
6 Surface 210			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											C Clay Surface 6		N Sandstone 6 101					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)		145 ft. _____ ground surface											10 in. above grade					
6 Steel			Surface		10. Pump Test											Developed ?					
4 Steel liner			6 101		Pumping level 170 ft. below surface											Disinfected ?					
Dia. (in.) Screen type, material & slot size			From (ft.) To (ft.)		Pumping at 11 GP for 2 Hrs.											Capped ?					
7. Grout or Other Sealing Material			Method		Pumping Method ?											12. Notified Owner of need to fill & seal ?					
Kind of Sealing Material			From (ft.) To (ft.) # Sacks Cement		Filled & Sealed Well(s) as needed?											13. Constructor / Supervisory Driller					
Neat Cement			Surface 6 101		Lic #											Date Signed					
Drill Rig Operator			Lic or Reg #		Date Signed																

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: