

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HF893		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner DAVID COLE					Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address RR#1, BOX 100					Town of FAIRFIELD		Street Address or Road Name and Number							
City BARABOO				State WI		Zip Code		Subdivision Name				Lot #		
County Sauk		Co. Permit #		Notification #		Completed 01-07-1987		Block #						
Well Constructor (Business Name) SAM VANDER GALIEN				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.53983 °N -89.62202 °W				Method Code GPS008		
Address				Well Plan Approval #		SE SE		Section 2		Township 12 N		Range 7 E		
Approval Date (mm-dd-yyyy)				or Govt Lot #		2. Well Type New Well								
Hicap Permanent Well #				Common Well #		Specific Capacity		of previous unique well #					constructed in	
3. Well serves # of Home				Hicap Well ?		Reason for replaced or reconstructed well ?								
Private, potable				Hicap Property ?		Construction Type								
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole					
8			Surface			80			Lower Open Bedrock					
6			80			85			Rotary - Mud Circulation					
Yes			Rotary - Air			Rotary - Air & Foam			Drill-Through Casing Hammer					
Reverse Rotary			Cable-tool Bit ___ in. dia...			Dual Rotary			Temp. Outer Casing ___ in. dia					
Removed? ___ depth ft. (If NO explain on back side)			Rotary - Air & Foam			Temp. Outer Casing ___ in. dia			Removed? ___ depth ft. (If NO explain on back side)					
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
S			Sand			Surface			10					
C			Clay			10			80					
S			Sand			80			85					
6. Casing, Liner, Screen														
Dia. (in.)			Material, Weight, Specification			From (ft.)			To (ft.)					
6			Steel			Surface			80					
Dia. (in.)			Screen type, material & slot size			From (ft.)			To (ft.)					
6			Steel			Surface			80					
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material			From (ft.)			To (ft.)			# Sacks Cement					
Drilling Mud and Cuttings			Surface			80			80					
9. Static Water Level														
16 ft. _____ ground surface														
10. Pump Test														
Pumping level 70 ft. below surface														
Pumping at 8 GP for 1 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ?														
Disinfected ?														
Capped ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #			Date Signed			Lic #			Date Signed					
Drill Rig Operator			Lic or Reg #			Date Signed			Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 07-12-2021

Review Status: