Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: 8HF903

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCOTT CARLINO			Phone #
Mailing Address: RR # 4			
City: PORTAGE	State: WI	Zip Code: 53562	
County: Sauk	Co. Permit #	Notification #	Completed: 01-10-1987

Well Constructor (Business Name): SAM VANDER GALIEN	Lic. #: 370	Facility ID # (Public Wells)	
Address: 150 RANDOLPH STREET, RANDOLPH WI 53956		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0	

1. Well Location

Town of FAIRFIELD			Fire # (if avail.): E14297
Street Address or Road Name and Number: SR 33			
Subdivision Name		Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.50254 °N -89.61079 °W — Method Code: GPS008

NE	SW	Section	Township	Range
or Govt Lot #		24	12 N	7 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	63
6	63	185

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
X	SAND & CLAY	Surface	15
Y	SAND & GRAVEL	15	62
R	QUARTZITE	62	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD AND CUTTINGS	Surface	63	

9. Static Water Level

40 ft. _____ ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 2 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? No

Disinfected ? No

Capped ? No

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: