

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HG244		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FRANKLIN BALLARD						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address						Town of SPRING GREEN						Street Address or Road Name and Number			
City SPRING GREEN				State WI		Zip Code									
County Sauk		Co. Permit #		Notification #		Completed 04-02-1969		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) DON O'CONNOR				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address				Well Plan Approval #				°N		°W		NW NW Section Township Range or Govt Lot # 5 8 N 4 E			
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity				2. Well Type New Well							
3. Well serves # of Farm Private, potable Heat Exchange ____ # of drillholes						Hicap Well ?		of previous unique well # constructed in							
						Hicap Property ?		Reason for replaced or reconstructed well ?							
Heat Exchange ____ # of drillholes						Hicap Potable ?		Construction Type							
						Hicap Potable ?		Construction Type							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)												
6 20 259															
6 20 259															
6 20 259															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S				Sand				Surface		224					
N				Sandstone				224		259					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 77 ft. ____ ground surface					
6		Steel				Surface		229							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 79 ft. below surface Pumping at 18 GP for 15 Hrs. Pumping Method ?					
6		Steel				Surface		229							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
Drilling Mud and Cuttings				Surface		20		20							
11. Well Is 10 in. above grade Developed ? Disinfected ? Capped ?															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-06-2021

Review Status: