

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HG387		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WILBERT VAN FOSSEN						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address RR # 1						Town of TROY						Street Address or Road Name and Number					
City SAUK CITY				State WI		Zip Code											
County Sauk		Co. Permit #		Notification #		Completed 08-04-1968		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) DON O'CONNOR				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.24204 °N -89.85355 °W				Method Code GPS008			
Address				Well Plan Approval #		NW SW		Section 24		Township 9 N		Range 5 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		24		9 N		5 E					
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in											
Heat Exchange ___ # of drillholes		Hicap Well ?		Hicap Property ?		Reason for replaced or reconstructed well ?											
Hicap Potable ?		Construction Type															
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
10 Surface 122			Rotary - Mud Circulation														
6 122 138			Rotary - Air														
			Rotary - Air & Foam														
			Drill-Through Casing Hammer														
			Reverse Rotary														
			Cable-tool Bit ___ in. dia...														
			Dual Rotary														
			Temp. Outer Casing ___ in. dia														
			Removed? ___ depth ft. (If NO explain on back side)														
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Q N				Caving sandstone				Surface		122							
H N				Firm Sandstone				122		138							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		Steel				Surface		122									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material										9. Static Water Level							
Method										75 ft. _____ ground surface							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is									
Neat Cement		Surface		120				12 in. above grade									
										10. Pump Test							
										Pumping level 76 ft. below surface				Developed ?			
										Pumping at 20 GP for 14 Hrs.							
										Pumping Method ?				Disinfected ?			
										Capped ?							
12. Notified Owner of need to fill & seal ?										Filled & Sealed Well(s) as needed?							
										13. Constructor / Supervisory Driller							
										Lic #				Date Signed			
										Drill Rig Operator							
										Lic or Reg #				Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-01-2023

Review Status: