

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HH248		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner HARRY HEARN					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address BOX 67					Town of IRONTON		Street Address or Road Name and Number						
City IRONTON				State WI		Zip Code		Subdivision Name				Lot #	
County Sauk		Co. Permit #		Notification #		Completed 11-11-1969		Block # 11					
Well Constructor (Business Name) JIM PARKHURST SR.				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W			
Hicap Permanent Well #				Common Well #		Specific Capacity		SE		Section 4			
Heat Exchange ___ # of drillholes				Hicap Well ?		Hicap Property ?		Township 12 N		Range 3 E			
3. Well serves # of Home				Private, potable		Hicap Potable ?		2. Well Type					
Reason for replaced or reconstructed well ?				Construction Type		of previous unique well # constructed in							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 34			Rotary - Mud Circulation										
6 34 75			Rotary - Air										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)		
C			Clay						Surface		15		
N			Sandstone						15		75		
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		Steel				Surface		36		35 ft. _____ ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										12 in. above grade			
7. Grout or Other Sealing Material										10. Pump Test			
Method										Pumping level 40 ft. below surface			
Kind of Sealing Material										Pumping at 8 GP for 0.5 Hrs.			
Neat Cement										Pumping Method ?			
From (ft.) To (ft.) # Sacks Cement										12. Notified Owner of need to fill & seal ?			
Surface 36										Filled & Sealed Well(s) as needed?			
										13. Constructor / Supervisory Driller			
										Lic #			
										Date Signed			
Drill Rig Operator										Lic or Reg #			
										Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-01-2023

Review Status: