

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HH453		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner FRED GERBER					Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address PO BOX 42 RR # 1							Town of EXCELSIOR							
City REEDSBURG					State WI		Zip Code							
County Sauk		Co. Permit #		Notification #		Completed 05-17-1957		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) FRED F. HAUGH				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.54061 °N -89.8985 °W				Method Code GPS008		
Address				Well Plan Approval #		SE SE		Section 4		Township 12 N		Range 5 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in								
						Reason for replaced or reconstructed well ?								
						Construction Type								
3. Well serves # of Other												Hicap Well ?		
Private, potable												Hicap Property ?		
Heat Exchange ___ # of drillholes												Hicap Potable ?		
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											
10 Surface 33			Rotary - Mud Circulation											
6 33 70			Rotary - Air											
			Rotary - Air & Foam											
			Drill-Through Casing Hammer											
			Reverse Rotary											
			Cable-tool Bit ___ in. dia...											
			Dual Rotary											
			Temp. Outer Casing ___ in. dia											
			Removed? ___ depth ft. (If NO explain on back side)											
8. Geology														
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)					
			I			Topsoil			Surface 1					
			S			Sand			1 15					
			N			Sandstone			15 70					
6. Casing, Liner, Screen														
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly					From (ft.) To (ft.)						
6 Steel								Surface 33						
Dia. (in.)			Screen type, material & slot size					From (ft.) To (ft.)						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement									
Puddled clay			Surface 20											
Cement			20 33											
9. Static Water Level														
12 ft. _____ ground surface														
10. Pump Test														
Pumping level 15 ft. below surface														
Pumping at 10 GP for 6 Hrs.														
Pumping Method ?														
11. Well Is														
16 in. above grade														
Developed ?														
Disinfected ?														
Capped ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
Lic #			Date Signed											
Drill Rig Operator			Lic or Reg #		Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 08-13-2024

Review Status: