

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8HH528		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BILL DICOT						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address						Town of EXCELSIOR															
City REEDSBURG						State WI		Zip Code													
County Sauk		Co. Permit #		Notification #		Completed 07-12-1969		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) ART HAWALLECK BYRON HACKER				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address				Well Plan Approval #		W SW		Section 11		Township 12 N		Range 5 E									
						or Govt Lot #															
Approval Date (mm-dd-yyyy)				2. Well Type of previous unique well # constructed in																	
				Reason for replaced or reconstructed well ?																	
Hicap Permanent Well #		Common Well #		Specific Capacity		Construction Type															
3. Well serves # of Home				Hicap Well ?																	
Private, potable				Hicap Property ?																	
Heat Exchange ____ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		22		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				S		Sand		Surface		1					
6		22		H				N		Hard Sandstone		1		96							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		36 ft. ____ ground surface				12 in. above grade							
6		Steel				Surface		22		10. Pump Test				Developed ?							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 45 ft. below surface				Disinfected ?							
										Pumping at 16 GP for 4 Hrs.				Capped ?							
										Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?									
Method												Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
Neat Cement				Surface		22															
												13. Constructor / Supervisory Driller				Lic #		Date Signed			
												Drill Rig Operator								Lic or Reg #	

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 06-30-2022

Review Status: