Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: 8MY064

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OSCAR SWAN	Phone #
Mailing Address: RFD 1	
City: OGEMA	State: WI Zip Code: 54459
County: Price	Co. Permit #:	Notification #:	Completed: 11-01-1943
Well Constructor (Business Name): CHRIS BRUNNER	Lic. #: 2400
Address: UNKNOWN STETSONVILLE WI 54480	
Hicap Permanent Well #:	Common Well #:

Facility ID # (Public Wells):
Well Plan Approval #:
Approval Date (mm-dd-yyyy):
Specific Capacity: 0.8

3. Well serves # of FARM
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of HILL
Fire # (if avail.): W3198
Street Address or Road Name and Number: RING SCHOOL RD.
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code
SE SW or Govt Lot # | Section: 2 | Township: 34 N | Range: 2 E

2. Well Type
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	281

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	RED CLAY	Surface	14
	HARDPAN	14	96
	RED CLAY & SAND MIXTURE	96	220
	HARDPAN	220	235
	RED CLAY, SAND & GRAVEL MIXTURE	235	276
	WATER BEARING SAND & GRAVEL	276	281

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD PIPE, STEEL SHOE	Surface	281
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

9. Static Water Level
81 ft. _____ ground surface

10. Pump Test
Pumping level 90 ft. below surface
Pumping at 7 GP M for 10 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? No
Disinfected ? No
Capped ? No

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-01-1960 Updated On: 10-15-2026 Review Status: