

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				8ND069		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner WILLIAM FISCHER						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address RR #1						Town of WINFIELD															
City REEDSBURG						State WI		Zip Code													
County Sauk		Co. Permit #		Notification #		Completed 08-26-1958		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) SUMNER FOGLE				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address				Well Plan Approval #		Approval Date (mm-dd-yyyy)		or Govt Lot #		Section 23		Township 13 N		Range 4 E							
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type of previous unique well # constructed in															
Hicap Well ?		Hicap Property ?		Hicap Potable ?		Reason for replaced or reconstructed well ?															
3. Well serves # of Other						Construction Type															
Private, potable																					
Heat Exchange ___ # of drillholes																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		29		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				X		Sandy Clay		Surface		6					
6		29		H S						Sandy shale		6		18							
				H N						Hard Sandstone		18		90							
				I N						White Sandstone		90		139							
6. Casing, Liner, Screen												8. Geology									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Steel				Surface		34.5													
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material												9. Static Water Level		11. Well Is							
Method												88 ft. _____ ground surface		18 in. above grade							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				10. Pump Test		Developed ?									
Neat Cement		Surface		34						Pumping level 90 ft. below surface		Disinfected ?									
												Pumping at 15 GP for 4 Hrs.		Capped ?							
												Pumping Method ?									
												12. Notified Owner of need to fill & seal ?									
												Filled & Sealed Well(s) as needed?									
						13. Constructor / Supervisory Driller		Lic #		Date Signed											
Drill Rig Operator						Lic or Reg #		Date Signed													

4a. Potential Contamination Sources

Is the well located in floodplain ?

Comment:

Created On: 01-01-1960

Updated On: 04-07-2021

Review Status: