

<b>Well Construction Report</b> <b>WISCONSIN UNIQUE WELL NUMBER</b>				<b>AAB516</b>		<b>Drinking Water and Groundwater - DG/5</b> <b>Department of Natural Resources, Box 7921</b> <b>Madison WI 53707</b>				Form 3300-077A			
Property Owner VILLAGE OF MAINE						Phone #		<b>1. Well Location</b>				Fire # (if avail.)	
Mailing Address 6111 N 44TH AVENUE								Village of MAINE					
City WAUSAU				State WI		Zip Code 54401							
County Marathon		Co. Permit #		Notification #		Completed 06-05-2020		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) SAM'S WELL DRILLING INC				Lic. # 370		Facility ID # (Public Wells) 737010780				Method Code GPS008			
Address PO BOX 150 N9935 PLEASANT RD RANDOLPH WI 53956				Well Plan Approval # 20181016		or Govt Lot #		Section 33		Township 30 N		Range 7 E	
				Approval Date (mm-dd-yyyy) 02-15-2019									
Hicap Permanent Well # 92494		Common Well #		Specific Capacity 4.2		<b>2. Well Type</b> New Well							
<b>3. Well serves</b> 1 # of MUNICIPAL WELL				Hicap Well ? Yes		of previous unique well # constructed in							
Municipal/Community				Hicap Property ? Yes		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ? Yes		Construction Type Drilled							
<b>4. Potential Contamination Sources - ON REVERSE SIDE</b>													
<b>5. Drillhole Dimensions and Construction Method</b>													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
16		Surface		53		<u>No</u> Rotary - Mud Circulation .....				<u>No</u>			
10		53		63		<u>No</u> Rotary - Air .....				<u>No</u>			
						<u>No</u> Rotary - Air & Foam .....				<u>No</u>			
						<u>No</u> Drill-Through Casing Hammer							
						<u>Yes</u> Reverse Rotary							
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>			
						<u>Yes</u> Dual Rotary .....				<u>No</u>			
						<u>Yes</u> Temp. Outer Casing 16in. dia							
						<u>Yes</u> Removed? 53depth ft. (If NO explain on back side)							
<b>8. Geology</b>													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
Y				Y-SAND & GRAVEL				Surface		60			
B Q				B-BROKEN Q-GRANITE				60		63			
<b>6. Casing, Liner, Screen</b>													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
10		STD BLK, PIPE, .365 WALL, P.E., A53B. BARBERSHOE				Surface		53					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
9		#25 STAINLESS STEEL TELESCOPING SCREEN WITH K-PACKER				52		63					
<b>7. Grout or Other Sealing Material</b>													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT GROUT				Surface		47		60 S					
<b>9. Static Water Level</b>													
17 ft. below ground surface													
<b>10. Pump Test</b>													
Pumping level 47 ft. below surface													
Pumping at 125 GP M for 8 Hrs.													
Pumping Method ? Test Pump													
<b>11. Well Is</b>													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
<b>12. Notified Owner of need to fill &amp; seal ?</b>												No	
Filled & Sealed Well(s) as needed?												No	
<b>13. Constructor / Supervisory Driller</b>						Lic #		Date Signed					
JVG						6026		06-08-2020					
<b>Drill Rig Operator</b>						Lic or Reg #		Date Signed					
RH						7375		06-05-2020					

#### 4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-08-2020

Created by: swdlabs

Updated On: 02-04-2021

Updated by: LILLIC