# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* AAB616

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: BOLIN, BRANT | Phone # |
| Mailing Address: P.O.BOX 273 | |
| City: FLORENCE | State: WI — Zip Code: 54121 |
| County: Florence | Co. Permit #: — Notification #: 7921461701 — Completed: 03-12-2020 |
| Well Constructor (Business Name): ROMITTI, JEREME | Lic. #: 6067 — Facility ID # (Public Wells): |
| Address: W8859 COUNTY N, NIAGARA WI 54151-0153 | Well Plan Approval #: — Approval Date (mm-dd-yyyy): |
| Hicap Permanent Well #: | Common Well #: — Specific Capacity: 0 |

**1. Well Location**

Town of COMMONWEALTH

Fire # (if avail.):

Street Address or Road Name and Number: COUNTY N

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 45.896 °N -88.243 °W — Method Code: GPS008

SE SE or Govt Lot # — Section: 33 — Township: 40 N — Range: 18 E

**2. Well Type** New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

**3. Well serves** # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 8 | Surface | 20 |
| 6 | 20 | 302 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| Yes | Rotary - Air ..... | Yes |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| R | M | S | | R-RED M-MEDIUM S-SAND | Surface | 8 |
| R | H | Z | Z | R-RED H-HARD/FIRM Z-CLAY & GRAVEL Z-W/COBBLES/BOULDERS | 8 | 43.5 |
| K | H | H | | K-BLACK H-HARD/FIRM H-SHALE | 43.5 | 302 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | WHEATLAND P.E. 18.97LB/FT A53B | Surface | 43.5 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | 43.5 | 3 S |

**9. Static Water Level**

50 ft. below ground surface

**10. Pump Test**

Pumping level 280 ft. below surface

Pumping at 1.5 GP M for 1 Hrs.

Pumping Method ? Airlift

**11. Well Is**

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| JR | 6067 | 03-17-2020 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| | | |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

Comment: PRESENTLY VACANT LAND WILL DO SAMPLES WHEN PUMP INSTALLED, PROBABLY JUNE 2020

Created On: 03-17-2020 Updated On: 04-10-2020 Review Status: APPROVED