

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAB618		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MILLER, CHRIS						Phone # (715)929-0290		1. Well Location				Fire # (if avail.)							
Mailing Address W7901 NOYES STREET						Town of PEMBINE						W7901							
City PEMBINE						State WI		Zip Code 54156				Street Address or Road Name and Number NOYES STREET							
County Marinette		Co. Permit #		Notification # 8084630101		Completed 07-24-2020		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) ROMITTI, JEREME				Lic. # 6067		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.6352 °N -87.9871 °W				Method Code GPS008					
Address W8859 COUNTY N NIAGARA WI 54151-0153				Well Plan Approval #		SE NW Section Township Range or Govt Lot # 34 37 N 20 E				2. Well Type Replacement									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ? POINT DRY													
3. Well serves # of HOME				Hicap Well ? No		Construction Type Drilled													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		8		No Rotary - Mud Circulation		No		T Q S		T-TAN/BROWN Q-CAVING S-SAND		Surface		12			
6		8		44		Yes Rotary - Air		No		T H Y		T-TAN/BROWN H-HARD/FIRM Y-SAND & GRAVEL		12		20			
						No Rotary - Air & Foam		No		T E S		T-TAN/BROWN E-CLEAN S-SAND		20		24			
						No Drill-Through Casing Hammer				T N M		T-TAN/BROWN N-FINE M-SILT		24		35			
						No Reverse Rotary				T N X		T-TAN/BROWN N-FINE X-SAND & CLAY		35		44			
						No Cable-tool Bit ___ in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface				14 in. above grade					
6		WHEATLAND A-53B P. E. 18.97 LB/FT STEEL				Surface		40		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 34 ft. below surface				Disinfected ? Yes					
6		STAI9NLESS STEEL K- PACKER #10				39		44		Pumping at 8 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method		MOUNDED										Filled & Sealed Well(s) as needed? Yes SEE REPORT							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
GRANULAR BENTONITE		Surface		40		4 S													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JJR				6067		08-06-2020	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		58	POWTS dispersal component (soil absorption unit or mound)	=	72

Comment:

Created On: 08-06-2020

Updated On: 09-08-2020

Review Status: APPROVED