Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAB618

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER, CHRIS	Phone #: (715)929-0290
Mailing Address: W7901 NOYES STREET	
City: PEMBINE	State: WI — Zip Code: 54156
County: Marinette	Co. Permit #:
Notification #: 8084630101	Completed: 07-24-2020
Well Constructor (Business Name): ROMITTI, JEREME	Lic. #: 6067
Facility ID # (Public Wells):	
Address: W8859 COUNTY N NIAGARA WI 54151-0153	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of PEMBINE	Fire # (if avail.): W7901
Street Address or Road Name and Number: NOYES STREET	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.6352 °N -87.9871 °W	Method Code: GPS008
SE NW or Govt Lot #:	Section: 34 — Township: 37 N — Range: 20 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: POINT DRY

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	8
6	8	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	12
T	H	Y		T-TAN/BROWN H-HARD/FIRM Y-SAND & GRAVEL	12	20
T	E	S		T-TAN/BROWN E-CLEAN S-SAND	20	24
T	N	M		T-TAN/BROWN N-FINE M-SILT	24	35
T	N	X		T-TAN/BROWN N-FINE X-SAND & CLAY	35	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A-53B P. E. 18.97 LB/FT STEEL	Surface	40
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	STAI9NLESS STEEL K- PACKER #10	39	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	40	4 S

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 34 ft. below surface

Pumping at 8 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

SEE REPORT

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJR	6067	08-06-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		58	POWTS dispersal component (soil absorption unit or mound)	=	72

Comment:

Created On: 08-06-2020 Updated On: 10-15-2026 Review Status: APPROVED