Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAB619

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KORNELY, MARK	Phone #: (920)973-4195
Mailing Address: 5916 PLEASANTVIEW LANE	
City: TWO RIVERS	State: WI — Zip Code: 54241
County: Marinette	Co. Permit #: — Notification #: 8093752401 — Completed: 09-22-2020
Well Constructor (Business Name): ROMITTI, JEREME	Lic. #: 6067 — Facility ID # (Public Wells):
Address: W8859 COUNTY N, NIAGARA WI 54151-0153	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of PEMBINE	Fire # (if avail.): N1880
Street Address or Road Name and Number: FOREST VIEW DRIVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.6371 °N -87.9631 °W	Method Code: GPS008

NW	NE	Section	Township	Range
or Govt Lot #		35	37 N	20 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	10
6	10	203

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	M	T-TAN/BROWN Q-CAVING S-SAND M-SILTY	Surface	12
R	H	K	C	R-RED H-HARD/FIRM K-COBBLES/BOULDERS C-CLAYEY	12	52
U	H	Q		U-BLUE H-HARD/FIRM Q-GRANITE	52	203

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	.280 WALL P.E. WHEATLAND A-53B NSF 61	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	52	4 S

9. Static Water Level
47 ft. below ground surface

10. Pump Test
Pumping level 180 ft. below surface
Pumping at 5 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJR	6067	10-21-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	75

Comment:

Created On: 10-21-2020 Updated On: 10-22-2020 Review Status: APPROVED